

AUTO-FLOW.

Laboratory and Fume Hood
Controls Engineering Guide

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Good Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

This energy savings projection form is a tool for calculating the energy cost comparisons of Constant Volume Hoods, Variable Volume Hoods and Variable Volume Hoods with an Automatic Sash Closure System to determine potential cost savings. Note: For calculation purposes it is inferred airflow control for the laboratory emulates fume hood airflow control (Variable Volume vs. Constant Volume)

Five Step Savings Projection:

- Step #1: Determining the expected average operator usage of the fume hoods in the laboratory facility.
- Step #2: Determine the Energy Costs associated with a Constant Volume Hood System.
- Step #3: Determine the Energy Costs associated with a Variable Volume Hood System.
- Step #4: Determine the Energy Costs associated with a Variable Volume Hood System with an Automatic Sash Closure System.
- Step #5: Compare the calculated energy costs of each system.

Step #1 Determining the expected average operator usage of the fume hoods in the laboratory facility.

| Enter Value | | | | |
|---------------------|--------------------|--|--------------------|-------------------|
| Sash Position | Percentage of Flow | Hours of Hood Use each Flow State per Week | | |
| | | Person at Hood | Person not at Hood | Total Hours Usage |
| Full Open | 100% | 1 | 0 | 1 |
| Partial Open | 66% | 4 | 30 | 34 |
| Closed | 20% | 0 | 133 | 133 |
| Total Hours >>>>>>> | | 5 | 163 | 168 |

| Sash Position | Percentage of Time |
|---------------|--------------------|
| Full Open | 1% |
| Partial Open | 20% |
| Closed | 79% |

AUTO-FLOW.

Laboratory and Fume Hood
Controls Engineering Guide

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Good Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Step #2 Determine The Energy Costs associated with a Constant Volume Hood System

Section #1 Collect the data listed below for the specific area, facility and system, and insert where indicated

| | | | |
|--|----------------|---|-------------|
| Facility Electrical Cost per Kilowatt-hour | \$ <u>0.10</u> | Required Hood Exhaust Volume | <u>1250</u> |
| Facility Average Heating Cost per MBTU | \$ <u>7.50</u> | Heating Degree Days (from ASHRAE) | <u>5588</u> |
| Facility Average Cooling Cost per MBTU | \$ <u>7.30</u> | Hood Exhaust Fan Motor Efficiency | <u>0.85</u> |
| Required Cooling MBTU's for selected Hood Volume | <u>40.68</u> | Horsepower of Hood Exhaust Fan or portion of total if manifolded system | <u>1</u> |

Section #2 This Section Calculates Heating Costs associated with selected Hood Volume

| | | | | | | | | | | |
|--------------------------------|---|-------------------------------|---|-------------------------------|---|---------------------------------------|---|----------|---------------|---------------------|
| \$ <u>7.50</u> | X | <u>5588</u> | X | <u>1250</u> | X | <u>168</u> | X | 0.154 | / 1,000,000 = | \$ <u>1,355</u> |
| Heating Cost (from Section #1) | | Degree Days (from Section #1) | | Hood Volume (from Section #1) | | Total Hours Weekly Use (from Part #1) | | Constant | | Annual Heating Cost |

Section #3 This Section Calculates Cooling Costs associated with selected Hood Volume

| | | | | | | | | | |
|---------------------------------|---|-------------------------------|---|---|---|--------------------------------|---|--------|---------------------|
| <u>3.36</u> | X | <u>1250</u> | X | <u>40.68</u> | X | \$ <u>7.30</u> | / | 1000 = | \$ <u>1,247</u> |
| Converted weekly operating time | | Hood Volume (from Section #1) | | Required cooling MBTU (from Section #1) | | Cooling Cost (from Section #1) | | | Annual Cooling Cost |

Section #4 This Section Calculates Fan Energy Costs (assume identical horsepower for make-up air fan requirements)

| | | | | | | | | | | |
|------------------|---|-----------------------------------|---|--|---|-------------------|---|------------------------------------|---|------------------------------------|
| <u>8760</u> | X | \$ <u>0.10</u> | X | <u>1</u> | X | 0.746 | / | <u>0.85</u> | = | \$ <u>769</u> |
| Annual Run Hours | | Electrical Cost (from Section #1) | | Exhaust Fan Horsepower (from Section #1) | | kw to hp constant | | Motor Efficiency (from Section #1) | | Annual Exhaust Fan Electrical Cost |
| <u>8760</u> | X | \$ <u>0.10</u> | X | <u>1</u> | X | 0.746 | / | <u>0.85</u> | = | \$ <u>769</u> |
| Annual Run Hours | | Electrical Cost (from Section #1) | | Make-up Fan Horsepower | | kw to hp constant | | Motor Efficiency (from Section #1) | | Annual Make-up Fan Electrical Cost |

Section #5 This Section Calculates the Total Annual Operating Costs associated with the Hood Model

| | | | | | | | | |
|---------------------|---|---------------------|---|------------------------------------|---|------------------------------------|---|-----------------------------|
| \$ <u>1,355</u> | + | \$ <u>1,247</u> | + | \$ <u>769</u> | + | \$ <u>769</u> | = | \$ <u>4,140</u> |
| Annual Heating Cost | | Annual Cooling Cost | | Annual Exhaust Fan Electrical Cost | | Annual Make-up Fan Electrical Cost | | Total Annual Operating Cost |

Section #6 This Section Calculates the Annual Cost per CFM

| | | | | |
|---|---|-----------------------------|---|---------------------|
| \$ <u>4,140</u> | / | <u>1250</u> | = | \$ <u>3.31</u> |
| Total Annual Operating Cost (from Section #5) | | Hood Volume from Section #1 | | Annual Cost per CFM |

AUTO-FLOW.

Laboratory and Fume Hood
Controls Engineering Guide

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Good Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Step #3 Determine the Energy Costs associated with a Variable Volume Hood System.

Section #1 Determine Total Hood Volume for each of the previously defined Sash Operating Positions

| Operating Position | Percent of Total Volume Flow | | Maximum Volume Flow | | VAV Flow |
|--------------------|-------------------------------|---|--|---|-----------------|
| Full Open | <u>100%</u> (from part #1) | X | <u>1250 CFM</u> (from part #2 Section #1) | = | <u>1250 CFM</u> |
| Partial Open | <u>66%</u> (from part #1) | X | <u>1250 CFM</u> (from part #2 Section #1) | = | <u>825 CFM</u> |
| Closed | <u>20%</u> (from part #1) | X | <u>1250 CFM</u> (from part #2 Section #1) | = | <u>250 CFM</u> |

Section #2 Determine the Average Flow Rate spread on a weekly basis

| Operating Position | Percent of Time | | VAV Flow | | Average Flow |
|--|------------------------------|---|--|---|----------------|
| Full Open | <u>1%</u> (from part #1) | X | <u>1250 CFM</u> (from Section #1 above) | = | <u>7 CFM</u> |
| Partial Open | <u>20%</u> (from part #1) | X | <u>825 CFM</u> (from Section #1 above) | = | <u>167 CFM</u> |
| Closed | <u>79%</u> (from part #1) | X | <u>250 CFM</u> (from Section #1 above) | = | <u>198 CFM</u> |
| Total Average Volume Flow Rate for this Hood | | | | | <u>372 CFM</u> |

Section #3 Determine the percentage of the Average VAV Flow to CAV Flow

| | | | | |
|---|---|--|---|--|
| <u>372 CFM</u> Average VAV Volume (from Section #2 above) | / | <u>1250 CFM</u> CAV Volume (from part #2 Section #1) | = | <u>30% CFM</u> Percent of VAV to CAV |
|---|---|--|---|--|

Section #4 Determine Annual VAV Hood Energy Costs

| | | | | |
|--|---|---|---|---|
| <u>\$ 1,355</u> Annual CAV Heating Cost (from part #2 Section #2) | X | <u>30%</u> Percent of VAV to CAV (from Section #3 above) | = | <u>\$ 404</u> Annual VAV Heating Cost |
| <u>\$ 1,247</u> Annual CAV Cooling Cost (from part #2 Section #3) | X | <u>30%</u> Percent of VAV to CAV (from Section #3 above) | = | <u>\$ 372</u> Annual VAV Cooling Cost |

continued next page

AUTO-FLOW.

ENERGY SAVINGS PROJECTION FORM

Laboratory and Fume Hood
Controls Engineering Guide

Project Name: Sample 6-foot Fume Hood with Good Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Step #4 continued

Determine Fan Electrical Energy Costs

| Operating Position | Percent of Total Volume Flow | | Percent of Time | | Average Fan Volume factor |
|-----------------------------|-------------------------------|---|------------------------------|---|------------------------------|
| Full Open | <u>100%</u> (from part #1) | X | <u>1%</u> (from part #1) | = | <u>0.0060</u> |
| Partial Open | <u>66%</u> (from part #1) | X | <u>20%</u> (from part #1) | = | <u>0.1336</u> |
| Closed | <u>20%</u> (from part #1) | X | <u>79%</u> (from part #1) | = | <u>0.1583</u> |
| Total VAV Fan Volume Factor | | | | | <u>0.2979</u> |

$$\begin{array}{rcl}
 \left(\begin{array}{l} \$ 769 \\ \text{Annual CAV} \\ \text{Exhaust Fan Cost} \\ \text{(from Part \#2 Section \#4)} \end{array} + \begin{array}{l} \$ 769 \\ \text{Annual CAV} \\ \text{Supply Fan Cost} \\ \text{(from Part \#2 Section \#4)} \end{array} \right) \times \begin{array}{l} 0.29786 \\ \text{VAV Fan} \\ \text{Factor} \\ \text{(from above)} \end{array} & = & \begin{array}{l} \$ 458.00 \\ \text{Annual VAV} \\ \text{Hood Fan Cost} \end{array}
 \end{array}$$

Calculate to Total VAV Hood Annual Operating Cost

$$\begin{array}{rcl}
 \begin{array}{l} \$ 404 \\ \text{Annual VAV} \\ \text{Heating Cost} \\ \text{(from this section} \\ \text{previous page)} \end{array} + \begin{array}{l} \$ 372 \\ \text{Annual VAV} \\ \text{Cooling Cost} \\ \text{(from this section} \\ \text{previous page)} \end{array} + \begin{array}{l} \$ 458 \\ \text{Annual VAV} \\ \text{Hood Fan Cost} \\ \text{(from this section)} \end{array} & = & \begin{array}{l} \$ 1,233.20 \\ \text{Annual VAV Hood} \\ \text{Operating Cost} \end{array}
 \end{array}$$

Section #5

Determine the Cost Differential of VAV Hood System vs. CAV Hood System

$$\begin{array}{rcl}
 \begin{array}{l} \$ 4,140 \\ \text{Total Annual CAV} \\ \text{Operating Cost} \\ \text{(from part \#2} \\ \text{Section \#5)} \end{array} - \begin{array}{l} \$ 1,233 \\ \text{Total Annual VAV} \\ \text{Operating Cost} \\ \text{(from above)} \end{array} & = & \begin{array}{l} \$ 2,907.05 \\ \text{Annual Savings} \\ \text{VAV vs. CAV} \\ \text{Hood System} \end{array}
 \end{array}$$

AUTO-FLOW.

Laboratory and Fume Hood
Controls Engineering Guide

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Good Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Step #4 Determining the Energy Costs associated with a VAV Hood with Automatic Sash Closure

Section #1 Determine Hood Use

| Hours of Hood Use each Flow State per Week | | | | |
|--|--------------------|--------------------------|---------------------------|--------------------------------|
| Sash Position | Percentage of Flow | Operator Present at Hood | Operator Absent from Hood | Total Hours use per flow state |
| Full Open | 1 | 1 | 0 | 1 |
| Partial Open | 0.66 | 4 | 30 | 34 |
| Closed | 0.2 | 0 | 133 | 133 |
| Total Hours >>>>>> | | 5 | 163 | 168 |

| Sash Position | Percentage of Time |
|---------------|--------------------|
| Full Open | 1% |
| Partial Open | 2% |
| Closed | 97% |

Adjusted Hours with Sash Automatically Closing when Operator is Absent from Hood

1
4
163

Section #2 Determine Total Hood Volume for each of the previously defined Sash Operating Positions

| Operating Position | Percent of Total Volume Flow | | Maximum Volume Flow | VAV Flow |
|--------------------|------------------------------|---|---------------------------|----------|
| Full Open | 100% | X | 1250 CFM | 1250 CFM |
| | (from Section #1) | | (from part #2 Section #1) | |
| Partial Open | 66% | X | 1250 CFM | 825 CFM |
| | (from Section #1) | | (from part #2 Section #1) | |
| Closed | 20% | X | 1250 CFM | 250 CFM |
| | (from Section #1) | | (from part #2 Section #1) | |

Section #3 Determine the Average Flow Rate spread on a weekly basis

| Operating Position | Percent of Time | | VAV Flow | Average Flow |
|--------------------|-------------------|---|-------------------------|--------------|
| Full Open | 1% | X | 1250 CFM | 7 CFM |
| | (from Section #1) | | (from Section #2 above) | |
| Partial Open | 2% | X | 825 CFM | 20 CFM |
| | (from Section #1) | | (from Section #2 above) | |
| Closed | 97% | X | 250 CFM | 243 CFM |
| | (from Section #1) | | (from Section #2 above) | |

Total Average Volume Flow Rate for this Hood

270 CFM

continued next page

AUTO-FLOW[®]

Laboratory and Fume Hood
Controls Engineering Guide

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Good Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Step #4 continued

Section #4 Determine the percentage of the Average VAV Flow to CAV Flow

$$\frac{270 \text{ CFM}}{\text{Average VAV Volume (from Section \#3 above)}} \div \frac{1250 \text{ CFM}}{\text{CAV Volume (from part \#2 Section \#1)}} = \frac{22\% \text{ CFM}}{\text{Percent of VAV to CAV}}$$

Section #5 Determine Annual VAV Hood Energy Costs

$$\frac{\$ 1,355}{\text{Annual CAV Heating Cost (from part \#2 Section \#2)}} \times \frac{22\%}{\text{Percent of VAV to CAV (from Section \#4 above)}} = \frac{\$ 292}{\text{Annual VAV Heating Cost}}$$

$$\frac{\$ 1,247}{\text{Annual CAV Cooling Cost (from part \#2 Section \#3)}} \times \frac{22\%}{\text{Percent of VAV to CAV (from Section \#4 above)}} = \frac{\$ 269}{\text{Annual VAV Cooling Cost}}$$

Determine Fan Electrical Energy Costs

| Operating Position | Percent of Total Volume Flow | | Percent of Time | | Average Fan Volume factor |
|-----------------------------|----------------------------------|---|---------------------------------|---|---------------------------------|
| Full Open | <u>100%</u> (from Section #1) | X | <u>1%</u> (from Section #1) | = | <u>0.0060</u> Full Volume |
| Partial Open | <u>66%</u> (from Section #1) | X | <u>2%</u> (from Section #1) | = | <u>0.0157</u> Partial Volume |
| Closed | <u>20%</u> (from Section #1) | X | <u>97%</u> (from Section #1) | = | <u>0.1940</u> Minimum Volume |
| Total VAV Fan Volume Factor | | | | | <u>0.2157</u> |

$$\left(\frac{\$ 769}{\text{Annual CAV Exhaust Fan Cost (from Part \#2 Section \#4)}} + \frac{\$ 769}{\text{Annual CAV Supply Fan Cost (from Part \#2 Section \#4)}} \right) \times \frac{0.2157}{\text{VAV Fan Factor (from above)}} = \frac{\$ 332}{\text{Annual VAV Hood Fan Cost}}$$

Calculate to Total VAV Hood with Sash Closure Annual Operating Cost

$$\frac{\$ 292}{\text{Annual VAV Heating Cost (from this section)}} + \frac{\$ 269}{\text{Annual VAV Cooling Cost (from this section)}} + \frac{\$ 332}{\text{Annual VAV Hood Fan Cost (from this section)}} = \frac{\$ 893.11}{\text{Annual VAV Hood with Sash Closure Operating Cost}}$$

continued next page

AUTO-FLOW®

*Laboratory and Fume Hood
Controls Engineering Guide*

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Good Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Section #5

Determine the Cost Differential of VAV Hood System vs. CAV Hood System

| | | | | |
|--|---|--|---|--|
| <u>\$ 4,140</u> | - | <u>\$ 893</u> | = | <u>\$ 3,247</u> |
| Total Annual CAV Operating Cost (from part #2 Section #5) | | Total Annual VAV Operating Cost (from Section #4 previous page) | | Annual Savings VAV vs. CAV Hood System |

AUTO-FLOW®

Laboratory and Fume Hood
Controls Engineering Guide

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Good Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Step #5 Summary of Operating Parameters & Energy Costs

SYSTEM DATA

| | | | |
|--|----------------|---|-------------|
| Facility Electrical Cost per Kilowatt-hour | <u>\$ 0.10</u> | Required Hood Exhaust Volume | <u>1250</u> |
| Facility Average Heating Cost per MBTU | <u>\$ 7.50</u> | Heating Degree Days (from ASHRAE) | <u>5588</u> |
| Facility Average Cooling Cost per MBTU | <u>\$ 7.30</u> | Hood Exhaust Fan Motor Efficiency | <u>0.85</u> |
| Required Cooling MBTU's for selected Hood Volume | <u>40.68</u> | Horsepower of Hood Exhaust Fan or portion of total if manifolded system | <u>1</u> |

CAV & VAV SASH OPERATION PARAMETERS

| Sash Position | Percentage of Flow | Hours of Hood Use each Flow State per Week | | Total Hours usage |
|--------------------|--------------------|--|--------------------|-------------------|
| | | Person at Hood | Person not at Hood | |
| Full Open | 100% | 1 | 0 | 1 |
| Partial Open | 66% | 4 | 30 | 34 |
| Closed | 20% | 0 | 133 | 133 |
| Total Hours >>>>>> | | 5 | 163 | 168 |

VAV WITH AUTOMATIC SASH CLOSURE SASH OPERATION PARAMETERS

| Sash Position | Percentage of Flow | Hours of Hood Use each Flow State per Week | | Total Hours usage |
|--------------------|--------------------|--|--------------------|-------------------|
| | | Person at Hood | Person not at Hood | |
| Full Open | 100% | 1 | 0 | 1 |
| Partial Open | 66% | 4 | 30 | 34 |
| Closed | 20% | 0 | 133 | 133 |
| Total Hours >>>>>> | | 5 | 163 | 168 |

continued next page

AUTO-FLOW.

*Laboratory and Fume Hood
Controls Engineering Guide*

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Good Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Step #5 continued

| Sash Position | Percentage of Time |
|---------------|--------------------|
| Full Open | 1% |
| Partial Open | 2% |
| Closed | 97% |

Adjusted Hours with Sash Automatically
Closing when Operator is Absent from Hood

1

4

163

Savings

Hood Type **Annual Cost
of Operation**

CAV \$ 4,140

VAV \$ 1,233

VAV w/ Closure \$ 893

VAV vs. CAV

\$ 2,907


VAV w/ Closure vs. CAV

\$ 3,247


VAV w/ Closure vs. VAV

\$ 340


FUME HOOD ANNUAL OPERATING COST COMPARISON



PROJECTED ANNUAL HOOD SAVINGS COMPARISON



PROJECTED ANNUAL SAVINGS COMPARISON FOR MULTIPLE HOOD PROJECTS



AUTO-FLOW.

Laboratory and Fume Hood
Controls Engineering Guide

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Average Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

This energy savings projection form is a tool for calculating the energy cost comparisons of Constant Volume Hoods, Variable Volume Hoods and Variable Volume Hoods with an Automatic Sash Closure System to determine potential cost savings. Note: For calculation purposes it is inferred airflow control for the laboratory emulates fume hood airflow control (Variable Volume vs. Constant Volume)

Five Step Savings Projection:

- Step #1: Determining the expected average operator usage of the fume hoods in the laboratory facility.
- Step #2: Determine the Energy Costs associated with a Constant Volume Hood System.
- Step #3: Determine the Energy Costs associated with a Variable Volume Hood System.
- Step #4: Determine the Energy Costs associated with a Variable Volume Hood System with an Automatic Sash Closure System.
- Step #5: Compare the calculated energy costs of each system.

Step #1 Determining the expected average operator usage of the fume hoods in the laboratory facility.

| "Enter Value" | | | | |
|---------------------|--------------------|--|--------------------|-------------------|
| Sash Position | Percentage of Flow | Hours of Hood Use each Flow State per Week | | |
| | | Person at Hood | Person not at Hood | Total Hours Usage |
| Full Open | 100% | 1 | 2 | 3 |
| Partial Open | 80% | 5 | 37 | 42 |
| Closed | 20% | 0 | 123 | 123 |
| Total Hours >>>>>>> | | 6 | 162 | 168 |

| Sash Position | Percentage of Time |
|---------------|--------------------|
| Full Open | 2% |
| Partial Open | 25% |
| Closed | 73% |

AUTO-FLOW.

Laboratory and Fume Hood
Controls Engineering Guide

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Average Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Step #2 Determine The Energy Costs associated with a Constant Volume Hood System

Section #1 Collect the data listed below for the specific area, facility and system, and insert where indicated

| | | | |
|--|---------|---|------|
| Facility Electrical Cost per Kilowatt-hour | \$ 0.10 | Required Hood Exhaust Volume | 1250 |
| Facility Average Heating Cost per MBTU | \$ 7.50 | Heating Degree Days (from ASHRAE) | 5588 |
| Facility Average Cooling Cost per MBTU | \$ 7.30 | Hood Exhaust Fan Motor Efficiency | 0.85 |
| Required Cooling MBTU's for selected Hood Volume | 40.68 | Horsepower of Hood Exhaust Fan or portion of total if manifolded system | 1 |

Section #2 This Section Calculates Heating Costs associated with selected Hood Volume

| | | | | | | | | | | |
|--------------------------------|---|-------------------------------|---|-------------------------------|---|---------------------------------------|---|----------|--------------|---------------------|
| \$ 7.50 | X | 5588 | X | 1250 | X | 168 | X | 0.154 | / 1,000,000= | \$ 1,355 |
| Heating Cost (from Section #1) | | Degree Days (from Section #1) | | Hood Volume (from Section #1) | | Total Hours Weekly Use (from Part #1) | | Constant | | Annual Heating Cost |

Section #3 This Section Calculates Cooling Costs associated with selected Hood Volume

| | | | | | | | | | | |
|---------------------------------|---|-------------------------------|---|---|---|--------------------------------|---|------|---|---------------------|
| 3.36 | X | 1250 | X | 40.68 | X | \$ 7.30 | / | 1000 | = | \$ 1,247 |
| Converted weekly operating time | | Hood Volume (from Section #1) | | Required cooling MBTU (from Section #1) | | Cooling Cost (from Section #1) | | | | Annual Cooling Cost |

Section #4 This Section Calculates Fan Energy Costs (assume identical horsepower for make-up air fan requirements)

| | | | | | | | | | | |
|------------------|---|-----------------------------------|---|--|---|-------------------|---|------------------------------------|---|------------------------------------|
| 8760 | X | \$ 0.10 | X | 1 | X | 0.746 | / | 0.85 | = | \$ 769 |
| Annual Run Hours | | Electrical Cost (from Section #1) | | Exhaust Fan Horsepower (from Section #1) | | kw to hp constant | | Motor Efficiency (from Section #1) | | Annual Exhaust Fan Electrical Cost |
| 8760 | X | \$ 0.10 | X | 1 | X | 0.746 | / | 0.85 | = | \$ 769 |
| Annual Run Hours | | Electrical Cost (from Section #1) | | Make-up Fan Horsepower | | kw to hp constant | | Motor Efficiency (from Section #1) | | Annual Make-up Fan Electrical Cost |

Section #5 This Section Calculates the Total Annual Operating Costs associated with the Hood Model

| | | | | | | | | |
|---------------------|---|---------------------|---|------------------------------------|---|------------------------------------|---|-----------------------------|
| \$ 1,355 | + | \$ 1,247 | + | \$ 769 | + | \$ 769 | = | \$ 4,140 |
| Annual Heating Cost | | Annual Cooling Cost | | Annual Exhaust Fan Electrical Cost | | Annual Make-up Fan Electrical Cost | | Total Annual Operating Cost |

Section #6 This Section Calculates the Annual Cost per CFM

| | | | | |
|---|---|-----------------------------|---|---------------------|
| \$ 4,140 | / | 1250 | = | \$ 3.31 |
| Total Annual Operating Cost (from Section #5) | | Hood Volume from Section #1 | | Annual Cost per CFM |

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Average Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Step #3 Determine the Energy Costs associated with a Variable Volume Hood System.

Section #1 Determine Total Hood Volume for each of the previously defined Sash Operating Positions

| Operating Position | Percent of Total Volume Flow | | Maximum Volume Flow | | VAV Flow |
|--------------------|-------------------------------|---|--|---|-----------------|
| Full Open | <u>100%</u> (from part #1) | X | <u>1250 CFM</u> (from part #2 Section #1) | = | <u>1250 CFM</u> |
| Partial Open | <u>80%</u> (from part #1) | X | <u>1250 CFM</u> (from part #2 Section #1) | = | <u>1000 CFM</u> |
| Closed | <u>20%</u> (from part #1) | X | <u>1250 CFM</u> (from part #2 Section #1) | = | <u>250 CFM</u> |

Section #2 Determine the Average Flow Rate spread on a weekly basis

| Operating Position | Percent of Time | | VAV Flow | | Average Flow |
|--------------------|------------------------------|---|--|---|----------------|
| Full Open | <u>2%</u> (from part #1) | X | <u>1250 CFM</u> (from Section #1 above) | = | <u>22 CFM</u> |
| Partial Open | <u>25%</u> (from part #1) | X | <u>1000 CFM</u> (from Section #1 above) | = | <u>250 CFM</u> |
| Closed | <u>73%</u> (from part #1) | X | <u>250 CFM</u> (from Section #1 above) | = | <u>183 CFM</u> |

Total Average Volume Flow Rate for this Hood 455 CFM

Section #3 Determine the percentage of the Average VAV Flow to CAV Flow

| | | | | |
|---|---|--|---|--|
| <u>455 CFM</u> Average VAV Volume (from Section #2 above) | / | <u>1250 CFM</u> CAV Volume (from part #2 Section #1) | = | <u>36% CFM</u> Percent of VAV to CAV |
|---|---|--|---|--|

Section #4 Determine Annual VAV Hood Energy Costs

| | | | | |
|--|---|---|---|---|
| <u>\$ 1,355</u> Annual CAV Heating Cost (from part #2 Section #2) | X | <u>36%</u> Percent of VAV to CAV (from Section #3 above) | = | <u>\$ 494</u> Annual VAV Heating Cost |
| <u>\$ 1,247</u> Annual CAV Cooling Cost (from part #2 Section #3) | X | <u>36%</u> Percent of VAV to CAV (from Section #3 above) | = | <u>\$ 454</u> Annual VAV Cooling Cost |

continued next page

AUTO-FLOW[®]

ENERGY SAVINGS PROJECTION FORM

Laboratory and Fume Hood
Controls Engineering Guide

Project Name: Sample 6-foot Fume Hood with Average Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Step #4 continued

Determine Fan Electrical Energy Costs

| Operating Position | Percent of Total Volume Flow | | Percent of Time | | Average Fan Volume factor |
|-----------------------------|-------------------------------|---|------------------------------|---|------------------------------|
| Full Open | <u>100%</u> (from part #1) | X | <u>2%</u> (from part #1) | = | <u>0.0179</u> |
| Partial Open | <u>80%</u> (from part #1) | X | <u>25%</u> (from part #1) | = | <u>0.2000</u> |
| Closed | <u>20%</u> (from part #1) | X | <u>73%</u> (from part #1) | = | <u>0.1464</u> |
| Total VAV Fan Volume Factor | | | | | <u>0.3643</u> |

$$\begin{array}{rcl}
 \left(\begin{array}{l} \$ 769 \\ \text{Annual CAV} \\ \text{Exhaust Fan Cost} \\ \text{(from Part \#2 Section \#4)} \end{array} + \begin{array}{l} \$ 769 \\ \text{Annual CAV} \\ \text{Supply Fan Cost} \\ \text{(from Part \#2 Section \#4)} \end{array} \right) \times \begin{array}{l} 0.36429 \\ \text{VAV Fan} \\ \text{Factor} \\ \text{(from above)} \end{array} & = & \begin{array}{l} \$ 560.14 \\ \text{Annual VAV} \\ \text{Hood Fan Cost} \end{array}
 \end{array}$$

Calculate to Total VAV Hood Annual Operating Cost

$$\begin{array}{rcl}
 \begin{array}{l} \$ 494 \\ \text{Annual VAV} \\ \text{Heating Cost} \\ \text{(from this section} \\ \text{previous page)} \end{array} + \begin{array}{l} \$ 454 \\ \text{Annual VAV} \\ \text{Cooling Cost} \\ \text{(from this section} \\ \text{previous page)} \end{array} + \begin{array}{l} \$ 560 \\ \text{Annual VAV} \\ \text{Hood Fan Cost} \\ \text{(from this section)} \end{array} & = & \begin{array}{l} \$ 1,508.24 \\ \text{Annual VAV Hood} \\ \text{Operating Cost} \end{array}
 \end{array}$$

Section #5 Determine the Cost Differential of VAV Hood System vs. CAV Hood System

$$\begin{array}{rcl}
 \begin{array}{l} \$ 4,140 \\ \text{Total Annual CAV} \\ \text{Operating Cost} \\ \text{(from part \#2} \\ \text{Section \#5)} \end{array} - \begin{array}{l} \$ 1,508 \\ \text{Total Annual VAV} \\ \text{Operating Cost} \\ \text{(from above)} \end{array} & = & \begin{array}{l} \$ 2,632.02 \\ \text{Annual Savings} \\ \text{VAV vs. CAV} \\ \text{Hood System} \end{array}
 \end{array}$$

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Average Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Step #4 Determining the Energy Costs associated with a VAV Hood with Automatic Sash Closure

Section #1 Determine Hood Use

| Hours of Hood Use each Flow State per Week | | | | |
|--|--------------------|--------------------------|---------------------------|--------------------------------|
| Sash Position | Percentage of Flow | Operator Present at Hood | Operator Absent from Hood | Total Hours use per flow state |
| Full Open | 1 | 1 | 2 | 3 |
| Partial Open | 0.8 | 5 | 37 | 42 |
| Closed | 0.2 | 0 | 123 | 123 |
| Total Hours >>>>>> | | 6 | 162 | 168 |

| Sash Position | Percentage of Time |
|---------------|--------------------|
| Full Open | 1% |
| Partial Open | 3% |
| Closed | 96% |

Adjusted Hours with Sash Automatically Closing when Operator is Absent from Hood

1
5
162

Section #2 Determine Total Hood Volume for each of the previously defined Sash Operating Positions

| Operating Position | Percent of Total Volume Flow | | Maximum Volume Flow | VAV Flow |
|--------------------|------------------------------|---|---------------------------------------|------------|
| Full Open | 100% (from Section #1) | X | 1250 CFM (from part #2 Section #1) | = 1250 CFM |
| Partial Open | 80% (from Section #1) | X | 1250 CFM (from part #2 Section #1) | = 1000 CFM |
| Closed | 20% (from Section #1) | X | 1250 CFM (from part #2 Section #1) | = 250 CFM |

Section #3 Determine the Average Flow Rate spread on a weekly basis

| Operating Position | Percent of Time | | VAV Flow | Average Flow |
|--------------------|--------------------------|---|-------------------------------------|--------------|
| Full Open | 1% (from Section #1) | X | 1250 CFM (from Section #2 above) | = 7 CFM |
| Partial Open | 3% (from Section #1) | X | 1000 CFM (from Section #2 above) | = 30 CFM |
| Closed | 96% (from Section #1) | X | 250 CFM (from Section #2 above) | = 241 CFM |

Total Average Volume Flow Rate for this Hood

278 CFM

continued next page

AUTO-FLOW[®]

Laboratory and Fume Hood
Controls Engineering Guide

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Average Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Step #4 continued

Section #4 Determine the percentage of the Average VAV Flow to CAV Flow

$$\frac{278 \text{ CFM}}{\text{Average VAV Volume (from Section \#3 above)}} \div \frac{1250 \text{ CFM}}{\text{CAV Volume (from part \#2 Section \#1)}} = \frac{22\% \text{ CFM}}{\text{Percent of VAV to CAV}}$$

Section #5 Determine Annual VAV Hood Energy Costs

$$\frac{\$ 1,355}{\text{Annual CAV Heating Cost (from part \#2 Section \#2)}} \times \frac{22\%}{\text{Percent of VAV to CAV (from Section \#4 above)}} = \frac{\$ 302}{\text{Annual VAV Heating Cost}}$$

$$\frac{\$ 1,247}{\text{Annual CAV Cooling Cost (from part \#2 Section \#3)}} \times \frac{22\%}{\text{Percent of VAV to CAV (from Section \#4 above)}} = \frac{\$ 278}{\text{Annual VAV Cooling Cost}}$$

Determine Fan Electrical Energy Costs

| Operating Position | Percent of Total Volume Flow | | Percent of Time | | Average Fan Volume factor |
|-----------------------------|----------------------------------|---|---------------------------------|---|---------------------------------|
| Full Open | <u>100%</u> (from Section #1) | X | <u>1%</u> (from Section #1) | = | <u>0.0060</u> Full Volume |
| Partial Open | <u>80%</u> (from Section #1) | X | <u>3%</u> (from Section #1) | = | <u>0.0238</u> Partial Volume |
| Closed | <u>20%</u> (from Section #1) | X | <u>96%</u> (from Section #1) | = | <u>0.1929</u> Minimum Volume |
| Total VAV Fan Volume Factor | | | | | <u>0.2226</u> |

$$\left(\frac{\$ 769}{\text{Annual CAV Exhaust Fan Cost (from Part \#2 Section \#4)}} + \frac{\$ 769}{\text{Annual CAV Supply Fan Cost (from Part \#2 Section \#4)}} \right) \times \frac{0.2226}{\text{VAV Fan Factor (from above)}} = \frac{\$ 342}{\text{Annual VAV Hood Fan Cost}}$$

Calculate to Total VAV Hood with Sash Closure Annual Operating Cost

$$\frac{\$ 302}{\text{Annual VAV Heating Cost (from this section)}} + \frac{\$ 278}{\text{Annual VAV Cooling Cost (from this section)}} + \frac{\$ 342}{\text{Annual VAV Hood Fan Cost (from this section)}} = \frac{\$ 921.70}{\text{Annual VAV Hood with Sash Closure Operating Cost}}$$

continued next page

AUTO-FLOW[®]

*Laboratory and Fume Hood
Controls Engineering Guide*

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Average Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Section #5

Determine the Cost Differential of VAV Hood System vs. CAV Hood System

| | | | | |
|--|---|--|---|--|
| <u>\$ 4,140</u> | - | <u>\$ 922</u> | = | <u>\$ 3,219</u> |
| Total Annual CAV Operating Cost (from part #2 Section #5) | | Total Annual VAV Operating Cost (from Section #4 previous page) | | Annual Savings VAV vs. CAV Hood System |

AUTO-FLOW.

*Laboratory and Fume Hood
Controls Engineering Guide*

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Average Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Step #5 Summary of Operating Parameters & Energy Costs

SYSTEM DATA

| | | | |
|--|----------------|---|-------------|
| Facility Electrical Cost per Kilowatt-hour | <u>\$ 0.10</u> | Required Hood Exhaust Volume | <u>1250</u> |
| Facility Average Heating Cost per MBTU | <u>\$ 7.50</u> | Heating Degree Days (from ASHRAE) | <u>5588</u> |
| Facility Average Cooling Cost per MBTU | <u>\$ 7.30</u> | Hood Exhaust Fan Motor Efficiency | <u>0.85</u> |
| Required Cooling MBTU's for selected Hood Volume | <u>40.68</u> | Horsepower of Hood Exhaust Fan or portion of total if manifolded system | <u>1</u> |

CAV & VAV SASH OPERATION PARAMETERS

| Sash Position | Percentage of Flow | Hours of Hood Use each Flow State per Week | | Total Hours usage |
|--------------------|--------------------|--|--------------------|-------------------|
| | | Person at Hood | Person not at Hood | |
| Full Open | 100% | 1 | 2 | 3 |
| Partial Open | 80% | 5 | 37 | 42 |
| Closed | 20% | <u>0</u> | <u>123</u> | <u>123</u> |
| Total Hours >>>>>> | | 6 | 162 | 168 |

VAV WITH AUTOMATIC SASH CLOSURE SASH OPERATION PARAMETERS

| Sash Position | Percentage of Flow | Hours of Hood Use each Flow State per Week | | Total Hours usage |
|--------------------|--------------------|--|--------------------|-------------------|
| | | Person at Hood | Person not at Hood | |
| Full Open | 100% | 1 | 2 | 3 |
| Partial Open | 80% | 5 | 37 | 42 |
| Closed | 20% | <u>0</u> | <u>123</u> | <u>123</u> |
| Total Hours >>>>>> | | 6 | 162 | 168 |

continued next page

AUTO-FLOW®

Laboratory and Fume Hood
Controls Engineering Guide

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Average Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Step #5 continued

| Sash Position | Percentage of Time |
|---------------|--------------------|
| Full Open | 1% |
| Partial Open | 3% |
| Closed | 96% |

Adjusted Hours with Sash Automatically Closing when Operator is Absent from Hood 1

5

162

Savings

Hood Type Annual Cost
 of Operation

CAV \$ 4,140

VAV \$ 1,508


VAV w/ Closure \$ 922

VAV vs. CAV \$ 2,632


VAV w/ Closure vs. CAV \$ 3,219

VAV w/ Closure vs. VAV \$ 587


FUME HOOD ANNUAL OPERATING COST COMPARISON



PROJECTED ANNUAL HOOD SAVINGS COMPARISON



PROJECTED ANNUAL SAVINGS COMPARISON FOR MULTIPLE HOOD PROJECTS



AUTO-FLOW.

*Laboratory and Fume Hood
Controls Engineering Guide*

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Poor Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

This energy savings projection form is a tool for calculating the energy cost comparisons of Constant Volume Hoods, Variable Volume Hoods and Variable Volume Hoods with an Automatic Sash Closure System to determine potential cost savings.
Note: For calculation purposes it is inferred airflow control for the laboratory emulates fume hood airflow control (Variable Volume vs. Constant Volume)

Five Step Savings Projection:

- Step #1: Determining the expected average operator usage of the fume hoods in the laboratory facility.
- Step #2: Determine the Energy Costs associated with a Constant Volume Hood System.
- Step #3: Determine the Energy Costs associated with a Variable Volume Hood System.
- Step #4: Determine the Energy Costs associated with a Variable Volume Hood System with an Automatic Sash Closure System.
- Step #5: Compare the calculated energy costs of each system.

Step #1 Determining the expected average operator usage of the fume hoods in the laboratory facility.

| "Enter Value" | | | | |
|---------------------|--------------------|--|--------------------|-------------------|
| Sash Position | Percentage of Flow | Hours of Hood Use each Flow State per Week | | |
| | | Person at Hood | Person not at Hood | Total Hours Usage |
| Full Open | 100% | 1 | 15 | 16 |
| Partial Open | 80% | 5 | 60 | 65 |
| Closed | 20% | 0 | 87 | 87 |
| Total Hours >>>>>>> | | 6 | 162 | 168 |

| Sash Position | Percentage of Time |
|---------------|--------------------|
| Full Open | 10% |
| Partial Open | 39% |
| Closed | 52% |

AUTO-FLOW.

Laboratory and Fume Hood
Controls Engineering Guide

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Poor Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Step #2 Determine The Energy Costs associated with a Constant Volume Hood System

Section #1 Collect the data listed below for the specific area, facility and system, and insert where indicated

| | | | |
|--|---------|---|------|
| Facility Electrical Cost per Kilowatt-hour | \$ 0.10 | Required Hood Exhaust Volume | 1250 |
| Facility Average Heating Cost per MBTU | \$ 7.50 | Heating Degree Days (from ASHRAE) | 5588 |
| Facility Average Cooling Cost per MBTU | \$ 7.30 | Hood Exhaust Fan Motor Efficiency | 0.85 |
| Required Cooling MBTU's for selected Hood Volume | 40.68 | Horsepower of Hood Exhaust Fan or portion of total if manifolded system | 1 |

Section #2 This Section Calculates Heating Costs associated with selected Hood Volume

| | | | | | | | | | | |
|-------------------|---|-------------------|---|-------------------|---|----------------|---|----------|---------------|---------------------|
| \$ 7.50 | X | 5588 | X | 1250 | X | 168 | X | 0.154 | / 1,000,000 = | \$ 1,355 |
| Heating Cost | | Degree Days | | Hood Volume | | Total Hours | | Constant | | Annual Heating Cost |
| (from Section #1) | | (from Section #1) | | (from Section #1) | | Weekly Use | | | | |
| | | | | | | (from Part #1) | | | | |

Section #3 This Section Calculates Cooling Costs associated with selected Hood Volume

| | | | | | | | | | |
|---------------------------------|---|-------------------|---|-----------------------|---|-------------------|---|--------|---------------------|
| 3.36 | X | 1250 | X | 40.68 | X | \$ 7.30 | / | 1000 = | \$ 1,247 |
| Converted weekly operating time | | Hood Volume | | Required cooling MBTU | | Cooling Cost | | | Annual Cooling Cost |
| | | (from Section #1) | | (from Section #1) | | (from Section #1) | | | |

Section #4 This Section Calculates Fan Energy Costs (assume identical horsepower for make-up air fan requirements)

| | | | | | | | | | | |
|------------------|---|-------------------|---|------------------------|---|-------------------|---|-------------------|---|------------------------------------|
| 8760 | X | \$ 0.10 | X | 1 | X | 0.746 | / | 0.85 | = | \$ 769 |
| Annual Run Hours | | Electrical Cost | | Exhaust Fan Horsepower | | kw to hp constant | | Motor Efficiency | | Annual Exhaust Fan Electrical Cost |
| | | (from Section #1) | | (from Section #1) | | | | (from Section #1) | | |
| 8760 | X | \$ 0.10 | X | 1 | X | 0.746 | / | 0.85 | = | \$ 769 |
| Annual Run Hours | | Electrical Cost | | Make-up Fan Horsepower | | kw to hp constant | | Motor Efficiency | | Annual Make-up Fan Electrical Cost |
| | | (from Section #1) | | | | | | (from Section #1) | | |

Section #5 This Section Calculates the Total Annual Operating Costs associated with the Hood Model

| | | | | | | | | |
|---------------------|---|---------------------|---|------------------------------------|---|------------------------------------|---|-----------------------------|
| \$ 1,355 | + | \$ 1,247 | + | \$ 769 | + | \$ 769 | = | \$ 4,140 |
| Annual Heating Cost | | Annual Cooling Cost | | Annual Exhaust Fan Electrical Cost | | Annual Make-up Fan Electrical Cost | | Total Annual Operating Cost |

Section #6 This Section Calculates the Annual Cost per CFM

| | | | | |
|-----------------------------|---|-----------------|---|---------------------|
| \$ 4,140 | / | 1250 | = | \$ 3.31 |
| Total Annual Operating Cost | | Hood Volume | | Annual Cost per CFM |
| (from Section #5) | | from Section #1 | | |

AUTO-FLOW.

Laboratory and Fume Hood
Controls Engineering Guide

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Poor Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Step #3 Determine the Energy Costs associated with a Variable Volume Hood System.

Section #1 Determine Total Hood Volume for each of the previously defined Sash Operating Positions

| Operating Position | Percent of Total Volume Flow | | Maximum Volume Flow | | VAV Flow |
|--------------------|-------------------------------|---|--|---|-----------------|
| Full Open | <u>100%</u> (from part #1) | X | <u>1250 CFM</u> (from part #2 Section #1) | = | <u>1250 CFM</u> |
| Partial Open | <u>80%</u> (from part #1) | X | <u>1250 CFM</u> (from part #2 Section #1) | = | <u>1000 CFM</u> |
| Closed | <u>20%</u> (from part #1) | X | <u>1250 CFM</u> (from part #2 Section #1) | = | <u>250 CFM</u> |

Section #2 Determine the Average Flow Rate spread on a weekly basis.

| Operating Position | Percent of Time | | VAV Flow | | Average Flow |
|--|------------------------------|---|--|---|----------------|
| Full Open | <u>10%</u> (from part #1) | X | <u>1250 CFM</u> (from Section #1 above) | = | <u>119 CFM</u> |
| Partial Open | <u>39%</u> (from part #1) | X | <u>1000 CFM</u> (from Section #1 above) | = | <u>387 CFM</u> |
| Closed | <u>52%</u> (from part #1) | X | <u>250 CFM</u> (from Section #1 above) | = | <u>129 CFM</u> |
| Total Average Volume Flow Rate for this Hood | | | | | <u>635 CFM</u> |

Section #3 Determine the percentage of the Average VAV Flow to CAV Flow

| | | | | |
|---|---|--|---|--|
| <u>635 CFM</u> Average VAV Volume (from Section #2 above) | / | <u>1250 CFM</u> CAV Volume (from part #2 Section #1) | = | <u>51% CFM</u> Percent of VAV to CAV |
|---|---|--|---|--|

Section #4 Determine Annual VAV Hood Energy Costs

| | | | | |
|--|---|---|---|---|
| <u>\$ 1,355</u> Annual CAV Heating Cost (from part #2 Section #2) | X | <u>51%</u> Percent of VAV to CAV (from Section #3 above) | = | <u>\$ 689</u> Annual VAV Heating Cost |
| <u>\$ 1,247</u> Annual CAV Cooling Cost (from part #2 Section #3) | X | <u>51%</u> Percent of VAV to CAV (from Section #3 above) | = | <u>\$ 634</u> Annual VAV Cooling Cost |

continued next page

AUTO-FLOW[®]

Laboratory and Fume Hood
Controls Engineering Guide

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Poor Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Step #4 continued

Determine Fan Electrical Energy Costs

| Operating Position | Percent of Total Volume Flow | | Percent of Time | | Average Fan Volume factor |
|--------------------|-------------------------------|---|------------------------------|---|---------------------------------|
| Full Open | <u>100%</u> (from part #1) | X | <u>10%</u> (from part #1) | = | <u>0.0952</u> Full Volume |
| Partial Open | <u>80%</u> (from part #1) | X | <u>39%</u> (from part #1) | = | <u>0.3095</u> Partial Volume |
| Closed | <u>20%</u> (from part #1) | X | <u>52%</u> (from part #1) | = | <u>0.1036</u> Minimum Volume |

Total VAV Fan Volume Factor

0.5083

$$\begin{array}{rcl}
 \left(\begin{array}{l} \$ 769 \\ \text{Annual CAV} \\ \text{Exhaust Fan Cost} \\ \text{(from Part \#2 Section \#4)} \end{array} + \begin{array}{l} \$ 769 \\ \text{Annual CAV} \\ \text{Supply Fan Cost} \\ \text{(from Part \#2 Section \#4)} \end{array} \right) \times \begin{array}{l} 0.50833 \\ \text{VAV Fan} \\ \text{Factor} \\ \text{(from above)} \end{array} & = & \begin{array}{l} \$ 781.63 \\ \text{Annual VAV} \\ \text{Hood Fan Cost} \end{array}
 \end{array}$$

Calculate to Total VAV Hood Annual Operating Cost

$$\begin{array}{rcl}
 \begin{array}{l} \$ 689 \\ \text{Annual VAV} \\ \text{Heating Cost} \\ \text{(from this section} \\ \text{previous page)} \end{array} + \begin{array}{l} \$ 634 \\ \text{Annual VAV} \\ \text{Cooling Cost} \\ \text{(from this section} \\ \text{previous page)} \end{array} + \begin{array}{l} \$ 782 \\ \text{Annual VAV} \\ \text{Hood Fan Cost} \\ \text{(from this section)} \end{array} & = & \begin{array}{l} \$ 2,104.63 \\ \text{Annual VAV Hood} \\ \text{Operating Cost} \end{array}
 \end{array}$$

Section #5

Determine the Cost Differential of VAV Hood System vs. CAV Hood System

$$\begin{array}{rcl}
 \begin{array}{l} \$ 4,140 \\ \text{Total Annual CAV} \\ \text{Operating Cost} \\ \text{(from part \#2} \\ \text{Section \#5)} \end{array} - \begin{array}{l} \$ 2,105 \\ \text{Total Annual VAV} \\ \text{Operating Cost} \\ \text{(from above)} \end{array} & = & \begin{array}{l} \$ 2,035.63 \\ \text{Annual Savings} \\ \text{VAV vs. CAV} \\ \text{Hood System} \end{array}
 \end{array}$$

AUTO-FLOW.

Laboratory and Fume Hood
Controls Engineering Guide

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Poor Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Step #4 Determining the Energy Costs associated with a VAV Hood with Automatic Sash Closure

Section #1 Determine Hood Use

| Hours of Hood Use each Flow State per Week | | | | |
|--|--------------------|--------------------------|---------------------------|--------------------------------|
| Sash Position | Percentage of Flow | Operator Present at Hood | Operator Absent from Hood | Total Hours use per flow state |
| Full Open | 1 | 1 | 15 | 16 |
| Partial Open | 0.8 | 5 | 60 | 65 |
| Closed | 0.2 | 0 | 87 | 87 |
| Total Hours >>>>> | | 6 | 162 | 168 |

| Sash Position | Percentage of Time |
|---------------|--------------------|
| Full Open | 1% |
| Partial Open | 3% |
| Closed | 96% |

Adjusted Hours with Sash Automatically Closing when Operator is Absent from Hood

1
5
162

Section #2 Determine Total Hood Volume for each of the previously defined Sash Operating Positions

| Operating Position | Percent of Total Volume Flow | | Maximum Volume Flow | = | VAV Flow |
|--------------------|------------------------------|---|---------------------------|---|----------|
| Full Open | 100% | X | 1250 CFM | = | 1250 CFM |
| | (from Section #1) | | (from part #2 Section #1) | | |
| Partial Open | 80% | X | 1250 CFM | = | 1000 CFM |
| | (from Section #1) | | (from part #2 Section #1) | | |
| Closed | 20% | X | 1250 CFM | = | 250 CFM |
| | (from Section #1) | | (from part #2 Section #1) | | |

Section #3 Determine the Average Flow Rate spread on a weekly basis

| Operating Position | Percent of Time | | VAV Flow | = | Average Flow |
|--------------------|-------------------|---|-------------------------|---|--------------|
| Full Open | 1% | X | 1250 CFM | = | 7 CFM |
| | (from Section #1) | | (from Section #2 above) | | |
| Partial Open | 3% | X | 1000 CFM | = | 30 CFM |
| | (from Section #1) | | (from Section #2 above) | | |
| Closed | 96% | X | 250 CFM | = | 241 CFM |
| | (from Section #1) | | (from Section #2 above) | | |

Total Average Volume Flow Rate for this Hood

278 CFM

continued next page

AUTO-FLOW[®]

Laboratory and Fume Hood
Controls Engineering Guide

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Poor Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Step #4 continued

Section #4 Determine the percentage of the Average VAV Flow to CAV Flow

$$\frac{278 \text{ CFM}}{\text{Average VAV Volume (from Section \#3 above)}} \div \frac{1250 \text{ CFM}}{\text{CAV Volume (from part \#2 Section \#1)}} = \frac{22\% \text{ CFM}}{\text{Percent of VAV to CAV}}$$

Section #5 Determine Annual VAV Hood Energy Costs

$$\frac{\$ 1,355}{\text{Annual CAV Heating Cost (from part \#2 Section \#2)}} \times \frac{22\%}{\text{Percent of VAV to CAV (from Section \#4 above)}} = \frac{\$ 302}{\text{Annual VAV Heating Cost}}$$

$$\frac{\$ 1,247}{\text{Annual CAV Cooling Cost (from part \#2 Section \#3)}} \times \frac{22\%}{\text{Percent of VAV to CAV (from Section \#4 above)}} = \frac{\$ 278}{\text{Annual VAV Cooling Cost}}$$

Determine Fan Electrical Energy Costs

| Operating Position | Percent of Total Volume Flow | | Percent of Time | | Average Fan Volume factor |
|-----------------------------|------------------------------|---|--------------------|---|---------------------------|
| Full Open | 100% | X | 1% | = | 0.0060 |
| | (from Section \#1) | | (from Section \#1) | | Full Volume |
| Partial Open | 80% | X | 3% | = | 0.0238 |
| | (from Section \#1) | | (from Section \#1) | | Partial Volume |
| Closed | 20% | X | 96% | = | 0.1929 |
| | (from Section \#1) | | (from Section \#1) | | Minimum Volume |
| Total VAV Fan Volume Factor | | | | | 0.2226 |

$$\left(\frac{\$ 769}{\text{Annual CAV Exhaust Fan Cost (from Part \#2 Section \#4)}} + \frac{\$ 769}{\text{Annual CAV Supply Fan Cost (from Part \#2 Section \#4)}} \right) \times \frac{0.2226}{\text{VAV Fan Factor (from above)}} = \frac{\$ 342}{\text{Annual VAV Hood Fan Cost}}$$

Calculate to Total VAV Hood with Sash Closure Annual Operating Cost

$$\frac{\$ 302}{\text{Annual VAV Heating Cost (from this section)}} + \frac{\$ 278}{\text{Annual VAV Cooling Cost (from this section)}} + \frac{\$ 342}{\text{Annual VAV Hood Fan Cost (from this section)}} = \frac{\$ 921.70}{\text{Annual VAV Hood with Sash Closure Operating Cost}}$$

continued next page

AUTO-FLOW[®]

*Laboratory and Fume Hood
Controls Engineering Guide*

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Poor Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Section #5

Determine the Cost Differential of VAV Hood System vs. CAV Hood System

| | | | | |
|--|---|--|---|--|
| <u>\$ 4,140</u> | - | <u>\$ 922</u> | = | <u>\$ 3,219</u> |
| Total Annual CAV Operating Cost (from part #2 Section #5) | | Total Annual VAV Operating Cost (from Section #4 previous page) | | Annual Savings VAV vs. CAV Hood System |

AUTO-FLOW.

ENERGY SAVINGS PROJECTION FORM

*Laboratory and Fume Hood
Controls Engineering Guide*

Project Name: Sample 6-foot Fume Hood with Poor Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Step #5 Summary of Operating Parameters & Energy Costs

SYSTEM DATA

| | | | |
|--|----------------|---|-------------|
| Facility Electrical Cost per Kilowatt-hour | <u>\$ 0.10</u> | Required Hood Exhaust Volume | <u>1250</u> |
| Facility Average Heating Cost per MBTU | <u>\$ 7.50</u> | Heating Degree Days (from ASHRAE) | <u>5588</u> |
| Facility Average Cooling Cost per MBTU | <u>\$ 7.30</u> | Hood Exhaust Fan Motor Efficiency | <u>0.85</u> |
| Required Cooling MBTU's for selected Hood Volume | <u>40.68</u> | Horsepower of Hood Exhaust Fan or portion of total if manifolded system | <u>1</u> |

CAV & VAV SASH OPERATION PARAMETERS

| Sash Position | Percentage of Flow | Hours of Hood Use each Flow State per Week | | Total Hours usage |
|--------------------|--------------------|--|--------------------|-------------------|
| | | Person at Hood | Person not at Hood | |
| Full Open | 100% | 1 | 15 | 16 |
| Partial Open | 80% | 5 | 60 | 65 |
| Closed | 20% | <u>0</u> | <u>87</u> | <u>87</u> |
| Total Hours >>>>>> | | 6 | 162 | 168 |

VAV WITH AUTOMATIC SASH CLOSURE SASH OPERATION PARAMETERS

| Sash Position | Percentage of Flow | Hours of Hood Use each Flow State per Week | | Total Hours usage |
|--------------------|--------------------|--|--------------------|-------------------|
| | | Person at Hood | Person not at Hood | |
| Full Open | 100% | 1 | 15 | 16 |
| Partial Open | 80% | 5 | 60 | 65 |
| Closed | 20% | <u>0</u> | <u>87</u> | <u>87</u> |
| Total Hours >>>>>> | | 6 | 162 | 168 |

continued next page

ENERGY SAVINGS PROJECTION FORM

Project Name: Sample 6-foot Fume Hood with Poor Sash Usage Discipline

Date: 2-Oct-95

Rep Name: SAMPLE CALCULATIONS

Step #5 continued

| Sash Position | Percentage of Time |
|---------------|--------------------|
| Full Open | 1% |
| Partial Open | 3% |
| Closed | 96% |

Adjusted Hours with Sash Automatically
Closing when Operator is Absent from Hood

1

5

162

Savings

Hood Type Annual Cost
 of Operation

CAV \$ 4,140

VAV \$ 2,105

VAV w/ Closure \$ 922

VAV vs. CAV

\$ 2,036


VAV w/ Closure vs. CAV

\$ 3,219


VAV w/ Closure vs. VAV

\$ 1,183

FUME HOOD ANNUAL OPERATING COST COMPARISON



PROJECTED ANNUAL HOOD SAVINGS COMPARISON



PROJECTED ANNUAL SAVINGS COMPARISON FOR MULTIPLE HOOD PROJECTS

